



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: November 6, 2009

Project: David L. Tippin WTF Solids Processing Lagoon Rehabilitation

Project No. 10-C-00015

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Revise Section 1 (General) of the Specific Provisions to read:

The Specific Provisions are intended as modifications or supplements to Instructions to Bidders, General Provisions and Agreement.

This is a 120 calendar day contract with the City of Tampa Water Department ("City" or "Department") for the rehabilitation of four (4) solids processing storm water lagoons at the David L. Tippin Water Treatment Facility. Work will include, but is not limited to the demolition and removal of existing pipe, pump structures and dredging of existing storm water ponds. The dredge material is ferric humate which is an iron organic sludge. This work also includes general cleanup.

Item 2: Revise Section 7 (Order and Time of Work) of the Specific Provisions to read:

The Contractor shall not be allowed to file claims for extra compensation of work prescribed by the Department. The Contractor will develop an overall schedule of work to be approved by the City of Tampa Water Department. The Contractor will coordinate the work schedule with the City. The order of work is at the discretion of the Contractor; nonetheless, all ponds cannot be taken out of service at the same time. Where any of the work requires an interruption of plant operation, permission must be received from the Department and the work performed at times designated by it. No services and/or work shall be rendered until the aforementioned provision has been met.

Item 3: Revise the last paragraph of Section 2.5 (Waste Material Disposal) of the Technical Specifications to read:

The Contractor is solely responsible for disposal of all construction debris and vegetation in accordance with all laws and regulations, and should obtain any additional information necessary to satisfy such requirements.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.


Jim Greiner, P.E., Contract Manager

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

TampaGov
www.tampagov.net