



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 3

DATE: July 26, 2010

Contract: 08-C-00021; Howard F. Curren AWTP Sludge Digester No. 6 Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: CHANGES TO SPECIFICATIONS:

Section W-13233 – Digester Covers, Part 2 – Products, Subsection 2.01 – Digester Cover Information, Item W-13233.2.01.D: Omit second sentence. Note: The 20-inch wide plate called for to be welded to the bottom chord of the digester cover trusses are not required here.

Item 2: CHANGES TO ADDENDUM #2:

Addendum #2, Item 2 - Changes to Specifications, note #7, second paragraph: Change the additional approved coating system for this project from Geothane 520 to Geothane 5020 and change the minimum tensile strength and elongation, in accordance with ASTM D 412, for this product to 1300 psi and 200% respectively. Note: This item pertains to the two paragraphs that were to be added at the end of Specifications Section W-9400 – Metal Surfaces Preparation and Coatings.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

Jim Greiner, P.E., Contract Manager