



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: May 7, 2009

Project: 42nd Street Pumping Station Rehabilitation

Contract No. 09-C-00006

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.


Item 1: Add the following note 7 to sheet 5 of the plans:

7. The tapping sleeve shall have A36 steel body and outlet in accordance with AWWA 200 and be designed to a working pressure of 150 PSIG. The tapping sleeve shall be epoxy coated in accordance with AWWA C-213. The tapping sleeve's outlet shall have an AWWA C-207 Class 'D' flange. All hardware shall be 304 stainless steel. The tapping sleeve shall be designed with circumferential Buna-N gasket to seal the outlet pipe. All welds shall be in accordance with AWWA standards.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.


Jim Grejner, P.E. Contract Manager
Contract Administration Department

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net