



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 2

DATE: August 20, 2009

Project: Howard F. Curren AWTP Sludge Digester No. 1 Rehabilitation

Contract No. 09-C-00025

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Add the following paragraph as the next to last paragraph in Subsection W-9401.06 Polymorphic Resin Systems in Section W-9401 (Revised) – Concrete Surfaces Preparation and Coating as issued by Addendum #1:

Epoxy coating systems will be considered equal to the specified Polymorphic Resin System provided that the material is a solvent-free, 100% solids epoxy and meets or exceeds the minimum physical properties listed above. Composite systems containing layers of different materials will not be considered as equal.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

Jim Greiner, P.E., Contract Manager  
Contract Administration Department