



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 2

DATE: August 26, 2009

Project: Wastewater Gravity Sewer Rehabilitation By Cured-in-Place Pipe (C.I.P.P.) FY10

Contract No. 10-C-00001

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Add the following sentence to section W - 52 Manhole Rehabilitation subsection W - 52.01:

A minimum thickness of 250 mils of the specified rehabilitation system shall be applied.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner, P.E., Contract Manager
Contract Administration Department