



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 2

DATE: April 26, 2010

Contract 10-C-00034; ARRA CDBG-R Green Building Upgrades to Community Facilities – Reroofing Upgrades at Wayne C. Papy Athletic Center

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Clarification – In Section 01010 – Summary of Work, 2.02 New Roof System – Roof Areas C1 & C3, there is no Detail 19.

Item 2: In Section 07600, 2.01 Prefabricated Metal Component Supplier, Items B and C, change all references to .050" aluminum to be 24 gauge stainless steel.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

  
Jim Greiner, P.E., Contract Manager