



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 4

DATE: July 13, 2011

Contract 11-C-00006; Sulphur Springs Pump Station Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: On Plan Sheet 4: Replace note R7 with the following:

R7. THE REPLACEMENTS SHALL BE P/N YT333160-901 CTS-HC-FR CORE, TANKS, SIDE, GASKET AS MANUFACTURED BY YOUNG TOUGHSTONE OF LEXINGTON, TN, OR APPROVED EQUAL. INSTALLATION SHALL INCLUDE NEW EXPANSION TANKS, SIZED AS RECOMMENDED BY THE MANUFACTURER. THE NEW CORES MAY CONSIST OF DUAL INFLOW AND OUTFLOW OUTLETS AS OPPOSED TO THE EXISTING SINGLE OUTLETS AS SHOWN. IF DUAL OUTLETS ARE CHOSEN, THE CONTRACTOR SHALL PROVIDE THE NECESSARY FITTINGS TO MAKE THE INTENDED PIPING CONNECTIONS. THE CONTRACTOR SHALL PROVIDE ANY NECESSARY BRACKETS, ANGLES, DRILLED HOLES, FASTENERS, ETC NECESSARY TO SECURE THE NEW ITEMS TO THE EXISTING SUPPORTS AS REQUIRED FOR A COMPLETE, FUNCTIONING, RADIATOR CORE REPLACEMENT

Item 2: Site visit, Friday July 15, 2011 from 10 am -12 pm. Bidders may visit the site during this time to familiarize themselves with the pump station conditions.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

Jim Greiner, P.E., Contract Manager