



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: March 22, 2011

Contract 11-C-00008; University Pumping Station – Pump No. 3
Replacement & Screen Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Replace the previously issued Workmanship and Materials Sections W-32.06 and W-32.07 with the following.

SECTION 32 – VALVES & TIED EXPANSION JOINT

W-32.06 Tied Expansion Joint

The expansion joints shall be heavy duty rated for a max. working pressure of 150 p.s.i. and shall be designed to withstand the corrosive environment typical of wastewater pump stations. Expansion joints shall have flanges with 316 stainless steel back-up rings. Flanges shall meet ANSI 125/150 standards. All hardware shall be 316 stainless steel. Tube and cover shall be Neoprene elastomer. Expansion control rods must be provided if necessary. Expansion joint shall be Style Invincible 501-FA as manufactured by Mercer Rubber Co. or approved equal.

W-32.07 Testing

All valves shall be given hydrostatic shop pressure tests at twice the working pressure specified. The valves shall be tested, first by applying the hydrostatic pressure with the valve open and then with the valve closed. The valves shall be tight and secure under the test pressure.

Valves (and expansion joint) shall be tested in place by the Contractor, as far as practicable, and any defects in valves or connections shall be corrected to the satisfaction of the Engineer.

Item 2: Note; The Architectural Scale for Plan Sheet No. 12 has been updated since its original posting.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.



Jim Greiner, P.E., Contract Manager

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net