



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 1

DATE: June 24, 2011

Contract 11-C-00022; 18<sup>th</sup> Street Wastewater Force Main Replacement By Directional Bore

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Question: Connection at existing lift station: Can the City divert flow during connection? If so, how long? How many GPD does the existing line move?

Response: No. The lift station will be shutdown (see note 4 sheet 2) during the tie-in.

Question: Can you please provide clarification on the following:

Bid Item #'s 0900-16, 0900-20, and 0900-24 require CL-150 pipe (which is DR-18), specification W24-1 requires DR-25 the detail on sheet 9 also refers to the PVC pipe as DR-25.

Response: The approved pipe must be C-905 DR-25 with a pressure rating of 165 psi.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

*Jim Greiner*

Jim Greiner, P.E., Contract Manager