



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 2

DATE: June 6, 2011

Contract 11-C-00025; Fire Station No. 1 Precast Panel Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Specifications, Instructions to Bidders, Section I-2.01, please notify the following **in advance** of desired site visit, even if access to the building is not required:

Frank J. Pfister, Maintenance & Specifications Officer, Tampa Fire Rescue,  
808 East Zack Street, Tampa, FL 33602; 813/274-7528 Office; 813/924-0246 Cell

Item 2: Specifications, Section 03312 – 3.06.C.: **CLARIFICATION** that 109 SF allowance of surface repairs is based on locations and areas defined on Sheet No's. S200 and S201 of the Drawings, and shall be included in the Base Bid.

Item 3: Drawings, Sheet No. S101:

- a. Detail D/S101: **ADD** "PROVIDE FLUSH END CAPS" to note related to railing ends.
- b. Detail F/S101: **DELETE** note "BEVEL ENDS OF DECK SURFACE".
- c. Detail G/S101: **CHANGE** note in parenthesis below height of scupper openings to read "(EXTEND MEMBRANE INTO OPENINGS)".

Item 4: Drawings, Sheet No. S200, Elevation A/S200: **CHANGE** boxed note regarding soffit patching to read "CONTRACTOR SHALL PATCH HOLES, ETC., NEEDED TO REMOVE/INSTALL PRECAST PANELS, INCLUDING TWO (2) EXISTING OPENINGS IN SOFFIT AT EACH PREVIOUSLY REMOVED PANEL – TYPICAL".

Item 5: Drawings, Sheet No. S201, Elevation B/S201: **CHANGE** boxed note regarding soffit patching to read "CONTRACTOR SHALL PATCH HOLES, ETC., NEEDED TO REMOVE/INSTALL PRECAST PANELS, INCLUDING TWO (2) EXISTING OPENINGS IN SOFFIT AT EACH PREVIOUSLY REMOVED PANEL – TYPICAL".

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

*Jim Greiner*

Jim Greiner, P.E., Contract Manager

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

