



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 3

DATE: August 11, 2011

Contract 11-C-00026; Ybor Pump Station Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

### RFI AND RESPONSES

Item 1: Question: It appears that the area required to set-up the bypass pumping system far exceeds the clouded footprint referenced on dwg G3. Please advise if the proposed bypass equipment layout area can be enlarged as needed.

Response: The area for the bypass pumping system can exceed the clouded area shown on the plans. Area required shall meet the needs of the bypass pumping system and the various requirements specified in the contract documents.

### Item 2: DRAWINGS

- 1) No. E5. In the AFD-P1 ONE LINE DIAGRAM where conduit 1AFDC1H terminates in a device labeled "TEMP", revise the text to read "THERMISTORS".
- 2) No. E8. In the SEWAGE PUMP P1 schematic diagram adjacent to the WINDING THERMISTORS, add the notation "TYPICAL FOR 6".
- 3) No. E17. Change the conduit and wiring in Conduit Numbers 1AFDC1F, 2AFDC1F, 3AFDC1F and 4AFDC1F from "3/4"C - 4#14, 1#14G" to "1"C - 14#14, 1#14G".
- 4) No. E17. Change the wiring in Conduit Numbers 1AFDC1H, 2AFDC1H, 3AFDC1H and 4AFDC1H from "2#14, 1#14G" to "12#14, 1#14G".
- 5) No. E17. Change the text in the "TO" column for Conduit Numbers 1AFDC1H, 2AFDC1H, 3AFDC1H and 4AFDC1H from "MOTOR TEMP SWITCH" to "MOTOR THERMISTORS".

Item 3: SPECIFICATIONS

- 1) Spec Section 16220. Revise the text in Paragraph 2.17, C. to read as follows.  
“PROVIDE REDUNDANT MOTOR WINDING THERMISTORS (SIX TOTAL) IN THE WINDINGS OF THE MOTORS FOR SEWAGE PUMPS P1, P2, P3 AND P4.
- 2) Spec Section 16266. Add Paragraph 2.6, F. to read as follows. THERMISTOR TERMINATIONS: CONNECT THE WIRING FOR THREE OF THE SIX MOTOR WINDING THERMISTORS TO THE WINDING MONITORING RELAY IN THE AFD. LAND THE WIRING FOR THE REMAINING THREE THERMISTORS ON A TERMINAL STRIP IN THE AFD AND LABEL AS SPARE.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [Contract Administration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

---

Jim Greiner, P.E., Contract Management Supervisor