



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 5

DATE: April 15, 2011

Contract 11-C-00033; Alline Avenue Stormwater Pump Station

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

PART 1 - SPECIFICATIONS

Item 1: Replace page P-3R with the attached page P-3RR

PART II – CLARIFICATIONS TO BIDDER QUESTIONS

Question: Bid item #1050-11424: 18" PVC Sanitary Sewer: 10 LF.
The plans call for 18 LF of 18" DIP.

Response: The Proposal Item, and the notes on plan sheets indicating 18" C-905 (DR-18) Green PVC Sanitary Sewer in Coachman Ave. are correct.

Question: The plan notes say all tree trimming and removal to be paid for in the Clearing & Grubbing item. There is no such item. Will a clear & grub item be added to include this scope of work.

Response: No separate item for Clearing and Grubbing will be included. Tree trimming and removal is included in each Contract Item affecting tree removal and trimming.

Question: Spec sect W-11.07, PVC Pipe Gravity, Post-Installation Tests, states that " The City shall perform the T.V. inspection only AFTER the pipelines have passed both the leakage and deflection tests." However, spec sect W-72-1, Television Inspection, seems to indicate that the Contractor is responsible for T.V. inspection of sewer manholes and pipe. Please clarify which entity is responsible for performing the T.V. inspections and associated costs.

Response: Contractor is responsible for TV inspections and all associated costs.

Question: We are receiving quotations on fencing for this project indicating confusion among bidders. Bid item #0550-10929 calls for 350 feet of pvc fence, as generally described by sheet c4 notes one and three. The first issue is there are two types of fencing called for and one bid item. The second issue is reconciling the qty of fence types required. Please clarify.

We would also appreciate clarification stating the fence required at the pump station(sheet Is-1, bid item 0448-73)is in no way duplicated on the west property line, with bid item #0550-10929.

Response: Contract Item 0550-10929 is for the PVC fencing on private property between Coachman Ave and Alline Ave. It is the fence detail on sheet LS-3 w/o the lattice top.

Contract Item 0448-73 is for the improvements on the pump station site and it includes the perimeter fencing and gates shown on sheets LS-1 and C-1. Contrary to the note on Sheet LS-3, the fence on the north, east, and south side of the pump station site is the plain PVC fence w/o the lattice top, and the fence on the west side is the PVC fence with the lattice top (matching the existing fence).

CLARIFICATION: MATERIALS TESTING

City forces will perform quality assurance materials testing for asphalt, soil density, and concrete, with a couple of exceptions. The Contractor shall provide an independent testing lab for QA testing of concrete and grout associated with structural components of the building, as detailed in the structural general notes. In addition, any other testing for verification of material properties, or to assure the warranty of the work, is the Contractor's responsibility and all costs associated therewith shall be included in the various contract item unit prices."

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [Contract Administration@tampagov.net](mailto:ContractAdministration@tampagov.net).



Jim Greiner, P.E., Contract Manager

Item No.	Description	Unit	Est Qty	Unit Price in Words	Unit Price	Total Price
0100-1	Contingency	LS	1	Six Hundred Thousand Dollars & No Cents	\$ 600,000	\$ 600,000
0101-1	Mobilization	LS	1	Two Hundred Fifty Thousand Dollars & No Cents	\$ 250,000	\$ 250,000
0102-1	Maintenance of Traffic	LS	1		\$	\$
0103-1	Erosion Control	LS	1		\$	\$
0104-1	Floating Silt Barrier	LF	190		\$	\$
0121-70	Flowable Fill	CY	100		\$	\$
0142-70	Additional Select Sand Fill Material	CY	100		\$	\$
0285-701	Permanent Pavement Base Replacement	SY	1500		\$	\$
0337-7-2	Permanent Pavement Surface Replacement	SY	2400		\$	\$
0350-2-1	Permanent Concrete Driveway Replacement	SY	150		\$	\$
0425-1551	Type E Inlet	EA	5		\$	\$
0425-1552	Inlet, Type 1 Top, Type E Bottom	EA	2		\$	\$
0425-1577	Grate Inlet with Type J Inlet Bottom	EA	1		\$	\$
0425-1801	Type 1 Inlet Top, Type J Inlet Bottom	EA	3		\$	\$
0425-2101	6' Diameter Manhole, Conflict Structure	EA	2		\$	\$
0425-2-41	6' Diameter Storm Drain Manhole	EA	2		\$	\$
0425-2-42	4' Diameter Storm Drain Manhole	EA	3		\$	\$
0425-3-81	Baffle Box	EA	2		\$	\$
0430-173115	15" RCP Storm Drain	LF	40		\$	\$
0430-173118	18" RCP Storm Drain	LF	40		\$	\$
0430-174124	24" RCP Storm Drain	LF	475		\$	\$
0430-175224	30" x 19" ERCP Storm Drain	LF	40		\$	\$
0430-175230	45" x 29" ERCP Storm Drain	LF	450		\$	\$