



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 2

DATE: September 13, 2011

Contract 11-C-00045; Branch Pump Station Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: The bypass pumps shall be sized to pump 1,200 gpm at 32 feet of TDH plus additional losses associated with the bypass pumping system.
- Item 2: Replace the Project Sign detail dated 10-09-2010 with the attached Project Sign detail dated 9/12/11.
- Item 3: The PCSR may be built by any certified UL 508 panel shop. All electrical components shall be UL listed and as specified, or as approved by the Engineer. A UL label shall be attached to the inside of the enclosure.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor



Project Manager :

Jim Hudock, PE
DPW Construction Engineer
City of Tampa

Phone : (813) 635-3400
Email : jim.hudock@tampagov.net

contractor name here

City of Tampa Improvement Project

brief project description (2 - 3 lines)

total appropriated cost (round off) - duration of construction

Scheduled for completion in *(date)*

supplemental project description (max. 2 lines)

For information, please call : (813) 635-3400

- NOTES :
1. Letter Color : Black, Font : **Times New Roman**, bold.
 2. Background Color (front, back and edges) : Benjamin Moore Paint, Natural Wicker OC-1.
 3. Post Color : Black.
 4. Contractor shall verify text with the City prior to sign fabrication.