



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: October 20, 2011

Contract: 11 - C-00053; Euclid Box Culvert Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: RFIs and Responses

Question: With regards to the spall repair pay item; is it an option for the contractor to use shotcrete/gunite application in lieu of hand troweling or form and pour/pump method?

Response: The Contractor shall bid the Contract as detailed and specified. Should the Contractor propose an alternate method that differs from that specified in the Contract Documents, the Contractor shall submit for approval at the time of the submittal review process a repair procedure for the alternate method referencing applicable standards, specifying the materials and equipment proposed. Mock-up testing of the alternate repair method shall be required to demonstrate the feasibility of the alternate method.

Question: With regards to the six drawings at the end of the package; there are legend symbols on the plans that show up fuzzy and hard to identify. Is it possible we can get a more clear, clean copy that we would be able to identify each type of symbol clearly as where laid out on plans?

Response: The Project Layout and Location Maps are posted in pdf format on the City's web site at the link below.

http://www.tampagov.net/dept_contract_administration

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net