



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 7 DATE: January 6, 2010

Project: Springhill Park Community Center
Project No. 7-C-59

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: Sheets A-6.1, A-6.2, A-6.4; Key Note #16; Replace reference to 3" metal roof deck with 1-1/2" metal roof deck.
- Item 2: Sheet A-10.1; Key Note #7; Delete the words "BY OWNER". Ice maker shall be included in the Base Bid price.
- Item 3: Sheet A-6.5; Key Note #21; 6'-0" x 6'-0" Grille at Entry is 19-SGF-2 Aluminum Flush Top Grating as manufactured by Ohio Grating, Inc.
- Item 4: Sheet LS-2; Fencing clarification; The Ameristar Aegis II Magestic fence and pedestrian gates around Splash Pad shall have ring adornment option. All other Aegis II fencing shall have third rail option. Vehicle gates shown on North 11th Street are 20'-0" wide rolling gates. All pedestrian gates for sidewalks 5'-0" are single leaf 5'-0" wide. All pedestrian gates for sidewalks wider than 5'-0" shall be double leaf and as wide as the sidewalk.
- Item 5: Sheet A-3.1; Detail C/A-3.1; Clarification; 3/4" pressure treated baseboard detail is to be similar to Detail F/A-13.1.
- Item 6: Specification Section 13125, page 22; Wall Panels, Ribbed Panels clarification; Basis of Design is 7.2 Panel by MCBI, Inc.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jody Gray

For Jim Greiner, P.E., Contract Manager

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

