



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 1

DATE: June 7, 2010

Contract 7-C-68; Robles Park Greenprinting Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Bid Clarification: The Bid shall consist of Base Bid and three Alternates as listed on the Proposal pages.

Disregard the various references to alternates on the Drawings. The retention pond as indicated, and board walk as indicated, are not part of the Project. Bidders shall follow proposal pages and specifications for bid response.

Item 2: Irrigation Clarification Sheet IR-1.1: Provide gate valve with 2" line stub out, as shown on northern portion of the Drawing for future tie-in. At the 1-1/2" gate valve adjacent, provide 1-1/4" stub-out for future tie-in. At the 2" gate valve adjacent to the 1-1/2" gate valve, provide 2" line stub-out for future tie-in.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

*Jim Greiner*

Jim Greiner, P.E., Contract Manager