



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1
DATE: June 22, 2009

Contract 08-C-00036; San Carlos Pump Station – Wet Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Site Visit:

A site visit will be held Wednesday June 24th at 10:00 AM at 4406 W. San Carlos Street, Tampa FL 33629.

Item 2: Hydro-Blasting Equipment:

The Contractor will be allowed to use Hydro-Blasting equipment for the rehabilitation of the wet well. Hydro-Blasting equipment may only be staged on the east side of the pumping station where it is farthest away from residential homes and as instructed by the Engineer. Contractor is responsible for complying with federal, state, and local noise regulations. The maximum noise level generated by the construction equipment shall not exceed 55 dBA. Contractor shall be responsible for constructing a noise suppression enclosure or other approved method to meet this requirement at no additional cost to the City.

Hydro-Blaster may only be used Monday through Friday between the hours of 8:00 AM and 3:00 PM.

Item 3: Stair Nosings:

On the plans, sheet 2, replace note 12 with the following:

12. All stair nosings shall be replaced with non-skid Fiberglass Stair Tread covers as manufactured by SeaSafe, stair repair aluminum & abrasive grit tread system type 500SN as manufactured by The Mat King, or approved equal.

On the plans, sheet 13, replace note 1 under "Stair Nosing Notes:" with the following:

1. Proposed stair nosings shall be Fiberglass Stair Tread covers as manufactured by SeaSafe of Lafayette, LA, Aluminum and Abrasive Grit Tread System type 500SN as manufactured by The Mat King of Long Island, NY, or approved equal.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Jim Greiner, P.E., Contract Manager