

METER SIZING CHART

Small motels without restaurant or convention facilities; apartments, condominiums, town houses, & small trailer parks less than 300 units; single doctors offices; nursing homes; A.C.L.F. & boarding homes; convents; sanatoriums:

Fixture Value Total	Meter Size	Flow (gpm)
0-45	¾" Displacement	0-20
46-565	1" Displacement	21-50
566-3000	1 ½" Displacement	51-75
3001-7150	1 ½" Displacement	76-100
7151-11000	2" Displacement	101-125
11001-14000	2" Displacement	126-150
14001-16000	2" Displacement	151-160
16001-23750	3" Turbine	161-200
23751-26000	3" Turbine	201-300
26001-60000	3" Turbine	301-450
60001-67500	4" Turbine	451-500

Other offices; hotels/motor inns; shopping centers; restaurants; public school; public buildings; hospitals; industrial; parks/attractions; large government installations; laundries; beauty shops; apartments, condominiums, townhouses, or trailer parks of 300 units or more; day care centers, churches:

Fixture Value Total	Meter Size	Flow (gpm)
0-25	¾" Displacement	0-20
26-105	1" Displacement	21-50
106-355	1 ½" Displacement	51-75
356-635	1 ½" Displacement	76-100
636-1070	2" Displacement	101-125
1071-2350	2" Displacement	126-150
2351-3600	2" Displacement	151-160
3601-10000	3" Turbine	161-200
10001-26000	3" Turbine	201-300
26001-48500	3" Turbine	301-450
48501-55500	4" Turbine	451-500

Flow rates for connection fee purposes are based on AWWA Manual 22.