



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

LETTER OF CLARIFICATION

AUGUST 15, 2008

Project: 06-C-00049; Interbay Pool ADA Improvements, PW6682

Bidders on the above referenced project are hereby notified that the following clarifications are made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Coated Chain Link Fencing General Note Clarification: Fencing shall be 6'0" high, 9 gauge metal per ASTM F 1043, with standard rails and 10 mils (min) Vinyl finish with Permafused II 15 year system warranty; similar to MasterHalco at www.fenceonline.com

All other provisions of the Contract Documents and Specifications not in conflict with this clarification shall remain in full force and effect.

Jim Greiner, P.E., Contract Manager
Contract Administration Department