



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

LETTER OF CLARIFICATION

OCTOBER 10, 2008

Project: 6-C-49 – REBID; Interbay Pool Restroom Renovations and Pool Deck Repair

Bidders on the above referenced project are hereby notified that the following clarifications are made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Foundation Stabilization Plan Sheet Clarification

Reference project note that refers to pumping soil cement/water mixture into void under slab, bidder should estimate that the grout intake for each location should be 50 cubic yards.

It should read that the grout intake should be 50 cubic yards maximum for the total of all 15 locations.

All other provisions of the Contract Documents and Specifications not in conflict with this clarification shall remain in full force and effect.



Jim Greiner, P.E., Contract Manager
Contract Administration Department

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net