



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 1

DATE: APRIL 21, 2008

Contract 08-C-00019, Howard F. Curren AWTP Sedimentation Tanks Rehabilitation, Phase 1

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

### PLANS

- Item 1: Sheet 4, Construction Notes / Air Piping Replacements: Add Note A-6 stating: "Contractor shall contain and dispose of debris from cleaning and preparing pipe as much as practicable. Paint shall be applied by brush or roller only. No spraying of paint will be permitted."
- Item 2: Sheet 15, Table "A": Air Piping Repair Sleeves and Supports Schedule: Change the required number of 6-inch repair sleeves from 1 to 4.

### CHANGES TO SPECIFICATIONS


- Item 3: Section 36- Painting, Page W36-2, Subsection W-36.04 Coatings, second paragraph: Change second sentence to read: Paint shall be applied by brush or roller in accordance with the manufacturer's recommendations; no spraying of paint will be permitted.
- Item 4: Section 55- Sludge Collector Equipment, Page W55-3, Subsection W-55.02.04 Collector Chain NCS-720-S-Sprockets, Item "B. Headshaft sprockets shall be ...": Change item #2 to read: "Headshaft sprockets shall match existing sprockets in pitch diameter and in number of teeth."
- Item 5: Section 55- Sludge Collector Equipment, Page W55-4, Subsection W-55.02.09 Wear Strips, Item "B": Change sentence to read: "Cross collector floor rail wear strips shall be mounted directly to steel rails embedded in the concrete floors and shall be attached with Type 316 Stainless Steel flat-head rivets in the same manner as the existing wear strips are attached.
- Item 6: Section 55- Sludge Collector Equipment, Page W55-4, Subsection W-55.02.11 NH-78 Drive and Driven Sprockets: Delete Items A, B and C.
- Item 7: Section 55- Sludge Collector Equipment, Page W55-5, Subsection W-55.02.11 NH-78 Drive and Driven Sprockets, Item "E: The driven bull sprocket shall be ...": Change item #2 to read: "Provide driven bull sprockets that match existing sprockets in pitch diameter and in number of teeth."

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

For questions concerning the above referenced project, please fax to 813/274-8080.

  
\_\_\_\_\_  
Jim Greiner, P.E., Contract Manager  
Contract Administration Department