



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 3

DATE: May 14, 2008

Project: Howard F. Curren AWTP Main Pumping Station Wet Well Rehabilitation

Project No. 08-C-00022

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.


Item 1: Change, on page W52-1, in Workmanship and Materials section W-52.04 Concrete Repair Materials, item 1, to read:

1. SikaTop 123 Plus – a two-component, polymer-modified, non-sag cementitious mortar intended for vertical and overhead surfaces. This product also contains FerroGard 901 penetrating corrosion inhibitor; or  
SikaRepair 224 – a one-component, cementitious mortar intended for repair of vertical and overhead surfaces. Formulated for application by trowel or low-pressure spray.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

For questions concerning the above referenced project, please fax to 813/274-8080.

  
\_\_\_\_\_  
Jim Grejner, P.E., Contract Manager  
Contract Administration Department

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

  
www.tampagov.net