



# CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 3

DATE: September 15, 2006

Contract 6-C-39; Swann Pumping Station Electrical Upgrade

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

### Workmanship and Materials

Item 1: Section 45 – Electrical – W45.01.2h – change second and third sentences to read: “The Contractor shall also have one (1) of the existing 240 VAC motors rewound, and shop tested at an experienced motor shop, to allow operation on 480 VAC, 3-phase – Provide a new stainless steel nameplate incorporating test result data. All three (3) existing motors shall be delivered to the Howard F. Curren AWT Plant as spares.”

### Drawings

Item 2: Sheet E3/5 – Existing Pump Room Plan  
Change second and third sentences of note at the top of sheet to read: “THE CONTRACTOR SHALL HAVE ONE OF THESE MOTORS REWOUND TO ALLOW OPERATION ON 480V, 3PH. DELIVER ALL THREE MOTORS TO THE HOWARD F. CURREN AWT PLANT AS SPARES.”

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions may be directed to Jim Greiner, P.E.; Telephone (813) 274-8598, fax (813) 274-8080, or e-mail [Jim.Greiner@tampagov.net](mailto:Jim.Greiner@tampagov.net).

Jim Greiner, P.E., Contract Manager  
Contract Administration Department