



CITY OF TAMPA

Pam Iorio, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: March 23, 2007

Contract 7-C-41; Wellwood Ballfield Lighting Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: The Bid Date for the above referenced project is hereby changed to April 10, 2007.
- Item 2: I-1.03 Time for Completion: Revise consecutive calendar days to 150.
- Item 3: TECO Allowance: Include in Base Bid price separate allowance of \$8,000.00 for TECO connection. Allowance use per Section 01020 of Specifications.
- Item 4: Underground Utilities Clarification: Contractor is responsible to locate all existing utilities on site. Provide documentation of utilities to the City of Tampa field representatives prior to start of work.
- Item 5: Wind Speed Change: Revise wind speed for 130 mph to 120 mph.
- Item 6: Transfer Clarification: Add \$10,000 allowance for disposal of existing transformers. Transformers are to be removed, and verified for disposal. Coordinate with field representative. Allowance use per Section 01020 of Specifications.
- Item 7: Field Grading/Repair Clarification: Add \$20,000 allowance for field grading. Prior to start of work, Contractor shall submit a site plan shop drawing illustrating proposed field access to minimize damage to fields during the work. Rough and final grading work shall restore fields to original condition. Contractor shall document existing conditions prior to start of work. Allowance use per Section 01020 of specifications.
- Item 8: City of Tampa Parks and Recreation Department will provide all sodding of fields damaged as a result of the work.
- Item 9: City of Tampa will remove and reinstall all fencing during course of project. Contractor shall reflect fence removal requirements on site plan shop drawing.
- Item 10: On-Off Light Control Wall Switches: Remove light control wall switches and related hardware, conduit and wiring for each of the eight lighting zones in the clubhouse. Per Sheet E-2 of construction documents and section 16140 wiring devices, Part 2.2 Wall Switches.

This addendum shall be included in and attached to the inside cover of the Contract Documents by and upon which bids are submitted.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions may be directed to Jim Greiner, P.E.; Telephone (813) 274-8598, fax (813) 274-8080, or e-mail Jim.Greiner@tampagov.net.



Jim Greiner, P.E., Contract Manager
Contract Administration Department

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net