



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

ADDENDUM NO. 5

DATE: September 8, 2015

12-C-00058; Channel District: 12th Street Wastewater Pump Station Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Question: In Addendum No. 2, Item #14, the question was posed as to the possibility of using the tremmie method for installation of the wet well. The use of this method would assume we would be allowed to change to an inside drop. Will the city allow the modification of their detail and the use of an inside drop?

Response: **CLARIFICATION** to Addendum No. 2, Item 14, that although the contractor is responsible for the means and methods, project details must comply with the City of Tampa Standards. City of Tampa Wastewater Department does not allow an inside drop connection.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor