



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: August 15, 2013

Contract 13-C-00037; Howard F. Curren AWTP Sludge Drying Bed Improvement – Sheltered Market

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Workmanship and Material Section 1 – Excavation clarification: Surplus excavated material can be disposed of onsite as approved and directed by the Engineer.

Item 2: Workmanship and Materials Section 2, Backfilling: Subsection W-2.14, delete paragraph and add the following:

All backfill shall be subject to test by the Contractor and approved by the Engineer. Contractor is responsible for all costs associated with testing.

Item 3: Plan Sheet No. 3, General Notes: General Project Data notes, under “Compaction” add the following:

The Contractor is responsible for all costs associated with testing.

Item 4: Plan Sheet No. 4, General Notes: Testing clarification: Pressure tests can be performed from the hose bibs back to the valve. A temporary blowoff does not need to installed.

Item 5: Attached for reference is the Pre-bid Meeting Sign-in Sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

13-C-00038; AWTP New Primary Sludge Pump Station Rehabilitation-Sheltered Market

E-Mail to Register as a Bidder and E-Mail All Questions to; ContractAdministration@tampagov.net

Sign-In Sheet Please Print

City of Tampa, Contract Administration Department

	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	jody.gray@tampagov.net
2	KERRICK Williams	KWP Construction Video	Kerrick@KWPConstructionVideo.com
3	Robert Lightsey	F.E.L. Inc	feckaren@comcast.net
4	Raymond Rogers	DANUS Utilities	Danus1@cfl.rr.com
5	PATRICK WELLS	FLORIDA SEALING PRO	pwells@floridasealing.com
6	Chris LANGFORD	L&L SITE SERVICES LLC	llsite@verizon.net
7	Jenny Langford	L&L Site Services LLC	llsite@verizon.net
8	Eddie Granger	Granger Maint.	eddie.granger@grangermaint.com
9	Mike Maloy	COT / CAD	813-323-2658
10	Rick Morriss	COT / CAD	813-630-3912
11	JESSICA McRony	ARTEVA Engineering	813-758-4465 jmcrony@arteva.com
12	Daniel Rivera	WW COT	813-274-8934 Daniel.Rivera@tampagov.net
13	JACK FERRAS	WW COT	813-274-3095
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			