



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 4

DATE: July 18, 2014

Contract: 14-C-00009; Krause Pump Station Rehabilitation.

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Clarification: The existing pumping station has an existing electric 5 ton overhead crane. The Contractor may utilize this crane as long as the load rating is not exceeded and temporary service is provided in accordance with SP-99 Temporary Electric Service Connections – which was included by Addendum No. 3.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect.

Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor