



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 2

DATE: October 8, 2014

Contract 14-C-00022; Howard F. Curren AWTP Mixed Sludge Pump Station Pump Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Section 95 – Screw Centrifugal Pumps, Section W-95.02 Pump Characteristics:
Replace W-95.02 Pump Characteristics with the following:

W-95.02 Pump Characteristics

The pumping unit shall be designed to pump mixed primary and secondary sludge with variable solids content and shall meet the following conditions:

RATING DATA

Number of Units: 1

Rating Capacity:

	Motor Speed (rpm)	Flow Rate (GPM)	TDH (ft)	Minimum Pump Efficiency
1st Point	1760	850	145	66%
2nd Point	1760	1675	84	65%

Approximate Shut-off Head
with Motor at 100% Speed 212 ft

Motor Horsepower 60 hp
Motor Speed 1760 rpm

Item 2: Section 95 – Screw Centrifugal Pumps, W-95.03 Construction Mechanical Seal: In the third sentence of the third paragraph replace 'P8412 carbon' with 'silicon carbide (RSC)'.

- Item 3: Section 95 – Screw Centrifugal Pumps, Section W-95.07 Shop Tests: In the second sentence of the first paragraph, change 'vertical' to 'horizontal'.
- Item 4: Clarification: The two-ton overhead crane that is currently on site is available for the Contractor to use for this project.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor