



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 4

DATE: April 24, 2015

Contract 15-C-00031; Ft. Brooke Parking Garage – Elevator Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: Specifications, Section 16721-1.2.A.1., 2.1.A., and 2.3.: **CLARIFICATION** that the Owner (City of Tampa) purchased equipment related to the Fire Alarm System shall be limited to the non-proprietary fire-alarm control unit provided by FIRE LITE (Model MS-9600VDLS with DACT-2VID), which shall be picked up, delivered to the site, and installed by the Contractor. The remainder of the system's equipment shall be compatible, including warranty.
- Item 2: Drawings, Sheet No. E-10, Fire Alarm General Notes, Note 1: **DELETE** the second sentence ("Any revisions and/or additions required ... will not be reason for additional compensation to the contractor.") in its entirety.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor