



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

ADDENDUM NO. 7

DATE: March 11, 2016

Contract 15-C-00037; Howard F. Curren AWTP Diffused Air Reactor Improvements, Phase I

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: Replace page P-3 with the attached Page P-3R.
- Item 2: Section 11225 Pier Mounted Vertical Turbine Mixers; paragraph 1.03(E): Delete sentence 1 in its entirety.
- Item 3: Section 11225 Pier Mounted Vertical Turbine Mixers; paragraph 1.03(E) 2: Replace the first sentence with the following: In order to qualify as an approved alternate, any mixer manufacturer must submit the following during project submittals:
- Item 4: Material and Debris Clarification:
- a. Material and Debris Removal from Existing Structures
 - i. Measurement for Material and Debris Removal will be based on the tons of material removed.
 - ii. Payment for Material and Debris Removal will be made at the Contract unit price per ton of dewatered material and debris removed and disposed of, which price and payment shall be for all labor, materials, supplies, equipment, fuel, disposal fees and all other incidentals necessary for all material and debris removal of 500 tons of materials from existing tank encountered during execution of the Work. Contractor shall dewater solids/debris, if required, to achieve minimum 15% solids content prior to transport and disposal. If requested by the Engineer, a sample from each truck shall be sent to an independent laboratory for percent solids analysis. Contractor shall be paid per ton of 15% solids or greater. Note that the quantity of 500 tons is only to obtain a unit cost for the items and may vary significantly from what is identified herein. No adjustments in the unit costs will be made to reflect changes in the quantities. Actual quantities for billing purposes shall be documented by the submittal of load tickets from the disposal site.
 - iii. The cost for this item is based on cost per ton of material removed and disposed

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

of (for 15% solids or greater), assuming 6-inches of sand/grit along entire floor of basin at 120 lbs/cf.

- iv. The City does not suspect any hazardous material to be present in the media to be removed and it, therefore, can be disposed of in a landfill. The City will test the media after the bid but before construction. In the unlikely event that hazardous material is detected, the City will utilize contingent funds to have the Contractor properly dispose of the material.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

Contract Item No.	Unit	Estimated Quantity	Description and Price in Words	Computed Price for Item in Figures
1. BASE BID	LS		<p>The work includes the furnishing all labor, materials and equipment to remove and replace aeration diffusers, mixers, vegetation, and associated appurtenances within reactor No.1, install internal recycle pump, backflow device, crane davit, and associated piping and appurtenances, install water quality probes (nitrate, ammonium, pH, DO) , PLC, air metering devices, and all associated electrical conduits, panels, and wiring, perform programming to automatically adjust air flow and internal recycle based on probe conditions defined by COT, perform SCADA integration, any allowances that may be listed in Section 01020, and with all associated work required for a complete project in accordance with the Contract Documents.</p> <p>_____ dollars and _____ cents</p>	
			(BASE BID) LS	\$ _____

2.	TON	500	Material and Debris Removal and Disposal	
			<p>_____ dollars and _____ cents</p>	\$ _____

Total Computed Price for Contract 15-C-00037 \$ _____