



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

## ADDENDUM 1

**DATE: December 6, 2018**

Contract 18-C-00012; HFC AWTP Administration Building Air Treatment System

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Specifications; Replace Proposal page P-2 with the attached Proposal page P-2R.

Item 2: Add the following Note "J" to Plans Sheet M102, General Notes:

J. Air duct routing and air duct support system shall be designed and installed so as to avoid disturbing the existing Aluminum Clad Base Flashing Membrane that is installed on the inner parapet walls (also exterior penthouse walls) and which transitions onto the roofing surfaces, extending approximately 10-inches out from each wall.

Item 3: Add the following Note "10" to Plans Sheet S100, General Structural Notes, Shop Drawings:

10. Air duct routing and air duct support system shall be designed and installed so as to avoid disturbing the existing Aluminum Clad Base Flashing Membrane that is installed on the inner parapet walls (also exterior penthouse walls) and which transitions onto the roofing surfaces, extending approximately 10-inches out from each wall.

Item 4: Plans Sheet S100, Detail S1-Duct Support Frame h<5'-0", Note #1, Change Note to read:

"All framing to be Stainless Steel."

Item 5: Plans Sheet S100, Detail S1-Duct Support Frame h<5'-0": Change "C7x5.96" to "C7x9.8" for horizontal channel beam at the top of the Support Frame structure.

Item 6: Plans Sheet S100, Detail S1-Duct Support Frame h<5'-0": Change "4.0x0.156-inch Pipe, Typ." to "4.0x0.226-inch Pipe, Typ." for vertical pipe columns at each end of the Support Frame structure.

Item 7: A copy of the Pre-Bid Conference sign-in sheet is attached for reference.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

Jim Greiner, P.E., Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080



Contract Item No.	Estimated Quantity	Description and Price in Words	Computed Total Price for Item in Figures
BASE BID	LS	<p>The work includes the furnishing of all labor, equipment, and material for the furnishing and installing an air duct piping and support system to relocate the existing air intake for air handler units (AHU) 1 and 3 at the HFC AWTP Administration Building, any allowances that may be listed in SP-60, and with all associated work required for a complete project in accordance with the Contract Documents.</p> <p>_____</p> <p>_____ dollars</p> <p>and _____ cents</p> <p>(BASE BID)      LS</p>	<p>\$ _____</p>

E-Mail to Register as a Plan Holder and E-Mail All Questions to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net)

Sign-In Sheet  Please Print

City of Tampa, Contract Administration Department

	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	jody.gray@tampagov.net
2	Michael Hampton	COT CAD	Michael.Hampton@Tampagov.net
3	Mark Johnson	COT CAP	mark.johnson@Tampagov.net
4	JAMES HENNESSY	COT WWD	JAMES.HENNESSY@TAMPAGOV.NET
5	Cassidy Barrett	COT WWD	CASSIDY.BARRETT@TAMPAGOV.NET
6	JACK FERRAS	COT WWD	JACK.FERRAS@TAMPA.NET
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			