



City of Tampa
Jane Castor, Mayor

Contract Administration
Michael W. Chucran, Director
306 East Jackson Street, 4N
Tampa, FL 33602

Office (813) 274-8116
Fax: (813) 274-7368

ADDENDUM 2

Via E-Mail

DATE: January 24, 2020

Contract 20-C-00005; Remote Storage Tank Improvements – Interbay

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: The bid opening date is hereby changed to February 4, 2020.

Item 2: Replace Proposal page P-2R with the attached page P-2RR.

Item 3: Plan Sheet No. 07 of 11, in the boxed NOTES, item 13. e. after “EPOXY”: Replace “...SPOT PRIMER WITH INTERMEDIATE FLUOROPOLYMER FINISH COAT...” with “...PRIMER (SPOT AND INTERMEDIATE COATS) WITH FLUOROPOLYMER FINISH COAT, PER SPECIFICATIONS.”.

Item 4: Clarification of Item 3 in Addendum 1: SSPC-QP2 Certification is not required for this project.

Item 5: Plan Sheet No. 7 of 11, in the boxed NOTES: Delete Item 2.

Item 6: Clarification of Item 6 in Addendum 1: Addendum 1 Item 6 removed the Proposal item for “Lead Removal” because until the specified lead based paint testing is completed (to be performed by the Contractor) the quantity of lead removals required is unknown. However, the requirement for lead testing (as specified in the Bid Documents) will remain in the contract, and any lead removals required will be compensated through the Owner Contingency as extra work.

Item 7: Specifications pg. 01025 – 6: Delete Item 16 in its entirety.

Item 8: Specifications Section 09900 PAINTING, 3.06 A. 3.: delete “sweep”.

Item 9: Plan Sheet No. 7 of 11, in the boxed NOTES, in Item 12. c.: Delete “sweep”.

Item 10: Clarification: Bid Item 4 directs coating select area of the tank’s exterior surface, approximated to be 8,000 sf. If the City elects to include the Alternate Exterior Tank Coating (Bid Item 15) then the entire exterior surface of the tank shall be coated, as 8000 sf will be compensated under Bid Item 4, and the rest under Bid Item 15. For further clarification of intent, see Specifications Section 01010 SUMMARY OF PROJECT, 1.01, and Section 01025, 1.04 MEASUREMENT AND PAYMENT.

Item 11: Specifications pg. 01025 – 4: Delete Item 11 in Section 01025, 1.04 in its entirety. Wear plate removal/installation is being deleted from project requirements. New/replacement wear plates will not be required

Item 12: Plan Sheet 06 of 11, in the plan view: Replace “City-provided, Contractor Installed” with “Contractor-provided and installed”.

Item 13: SECTION 01025 MEASUREMENT AND PAYMENT, pg. 01025 – 3, 1.04 A., 7. a. Add the following: Contractor shall pick-up the palletized and shrink-wrapped sleeve valve from the David L. Tippin Water Treatment Plant at 7125 N. 30th Street, Tampa, FL 33610. Contact Roy McKenzie at 813-323-4200 to schedule pick-up.

Item 14: SECTION 01505 MOBILIZATION, 1.01 A. – add the following: 13. Schedule with City to pick-up Owner-procured palletized Sleeve Valve from the from the David L. Tippin Water Treatment Plant at 7125 N. 30th Street, Tampa, FL 33610. Contact Roy McKenzie at 813-323-4200 to schedule pick-up.

Item 15: Attached are copies of the U-WMBE and SLBE Availability Contact Lists, edited to print more legibly.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

Itemized Bid Sheet						
Item	Description	Approx. Quantity	Unit	Unit Price in Words	Unit Price	Total Price
1	General Conditions	1	LS		\$	\$
2	Mobilization/Demobilization	1	LS		\$	\$
3	Permitting, Bonds, and Insurance	1	LS		\$	\$
Tank Coating						
4	Exterior Tank and Ladder Surface Preparation and Coating	8,000	SF		\$	\$
5	Interior Tank and Ladder Surface Preparation and Coating (approx. 51,000 sf)	1	LS		\$	\$
6	Disinfection and Testing	1	LS		\$	\$
Mechanical Improvements						
7	Removal of Altitude Control Valve and Installation of Owner-Provided Sleeve Valve	1	LS		\$	\$
8	Removal and Replacement of 24" Valves, Installation of Dismantling Joint and Spool Pieces	1	LS		\$	\$
9	Removal and Replacement of 24-inch Yard Piping and Isolation Valves	1	LS		\$	\$
10	Concrete Pad Removal and Replacement	1	LS		\$	\$
12	Contingency			One Hundred Ten Thousand Dollars and Zero Cents	\$ 110,000	\$ 110,000
					Subtotal Base Bid	
Alternate						
13	Sleeve Valve Electrical and Programming	1	LS		\$	\$
14	Interior Tank - Wall Coating and Surface Preparation (areas not coated in Bid Item #5)	1	LS		\$	\$
15	Exterior Tank - Full Fluoropolymer Coating (areas not coated in Bid Item #4)	1	LS		\$	\$
17	Alternate Contingency			Fifty Three Thousand Four Hundred Dollars and Zero Cents	\$ 53,400	\$ 53,400
					Subtotal Alternate	
					Total: Base Bid + Alternate	

Remote Storage Tank Improvements - Interbay

FY 20 Project 20-C-00005

U-WMBE Availability Contact List

(The Underutilized WMBE Industry Category for Construction Subcontracts is BBE)

This Certified Contact List is the minimum contacts available and may require further searches for certified firms to meet Good Faith Efforts.												
#'s	Business Name	Phone	Fax	Email	Address 1	City	State	Zip	Business Description	FEIN	Typ	Ethnicity
1	DRD Enterprises LLC	813-476-9933	866-850-1332	ddeenah@drdenterprises.com	4104 Yellowwood Dr.,	Valrico	FL	33594	Pipe Supply	204675317	BBE	African American
1	MANZI METALS INC	352-799-8211	352-754-9735	bmanzi@manzimetals.com	15293 FLIGHT PATH DR	BROOKSVILLE	FL	34604	Pipe Supply	593245008	BBE	African American
1	Suca Pipe Supply, Inc.	813-249-7902		simau44@yahoo.com	4910 Lowell Rd	Tampa	FL	33624	Pipe Supply	592499571	BBE	African American
1	Suca Pipe Supply, Inc. One	813-249-7902		mactwinau1@yahoo.com	4910 Lowell Road	Tampa	FL	33624	Pipe Supply	263669556	BBE	African American
1	Terrell Industries, Inc.	727-823-4424	727-823-3977	gradyterrell@terrellindustries.com	2067 1ST AVENUE NORTH	ST PETERSBURG	FL	33713	Pipe Supply	650530148	BBE	African American
2	ECO 2000 INC	352-793-5060	352-793-9074	WATERWORKS@ECO2000INC.COM	1611 W C-48	BUSHNELL	FL	33513	Pipe Supply	593648996	BBE	African American
2	Mckenzie Contracting LLC	813-454-4429	813-454-4429	valarie@mckenziecontractingllc.com	7712 W Broadway Ave	Tampa	FL	33619	Pipe Supply	463561860	BBE	African American
3	Provisions Construction & Development, Inc.	407-985-2442	407-985-2440	marrington@provisionscdi.com	3401 Lake Breeze Drive Bldg 601	Orlando	FL	32808	Concrete	462802435	BBE	African American
4	All In One Electric Inc	813-849-6331	813-514-0473	rjones@aibelectric.com	1201 W WATERS AVENUE	TAMPA	FL	33604	Programming a	043689273	BBE	African American
4	Brown & Brown Electric, Inc.	954-938-8986	954-938-9272	Hermine.Brown@brownandbrownelectric.com	1150 SW 30th Avenue	Pompano Beach	FL	33069	Programming a	592283934	BBE	African American
4	MDH Enterprises, Inc.	386-789-2672	866-681-5026	matize@my-es.com	281 East C Street	Orange City	FL	32763	Programming a	550849332	BBE	African American

