



City of Tampa
Jane Castor, Mayor

Contract Administration
Michael W. Chucran, Director
306 East Jackson Street, 4N
Tampa, FL 33602

Office (813) 274-8116
Fax: (813) 274-7368

ADDENDUM 3

Via E-Mail

DATE: January 30, 2020

Contract 20-C-00005; Remote Storage Tank Improvements – Interbay

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: The bid opening date is hereby changed to February 11, 2020.

Item 2: Clarification of Item 12 in Addendum 2: ...Plan Sheet 06 of 11, in the plan view: Replace “City-provided, Contractor Installed” with “Contractor-provided and installed”... applies only to the proposed 24” Plug Valve, not to the Sleeve Valve. The Sleeve Valve remains City-Provided, Contractor Installed. The only material required for this project to be provided by the City is the Sleeve Valve.

Item 3: On Plan Sheet 6 of 11, in the plan view: delete LINK SEAL (TYP.X2). The outlet flange on the tank is to remain.

Item 4: On Plan Sheet 6 of 11, in the plan view: delete WELDED FLANGED OUTLET, REPLACE IN KIND (AS SHOWN IN PHOTO). The existing flanged outlet on the tank is to remain.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor