## **CITY OF TAMPA**



Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: August 15, 2013

Contract 13-C-00038; Howard F. Curren AWTP New Primary Sludge Pump Station Rehabilitation – Sheltered Market

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Electrical Clarification; Plan Sheet No. 3, General Notes: add the following note:

## **ELECTRICAL**

Electrical work is limited to disconnecting and re-connecting electrical facilities in order to perform the work described in the Specifications and Plans. The Engineer considers this electrical work incidental to the mechanical work and therefore limited electrical information is provided in the Contract Documents. All conduits and wires demolished during construction shall be replaced in kind and reconnected as required to provide a system that functions the same as prior to demolition. The extent of conduit and wire replacement will lie in the general vicinity of the pumping station. Aluminum or stainless steel NEMA 4X boxes shall be provided, where necessary, to facilitate splicing of the new conductors to feeder/source conductors. Contractor shall submit for approval, shop drawings and cut sheets for all proposed electrical equipment. All electrical work shall be performed pursuant to the latest National Electrical Code (NEC) by a licensed Electrician.

Item 2: Attached for referenced is the Pre-bid Meeting Sign-in Sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

<u> Jim Greiner</u>

Jim Greiner, P.E., Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080



## 13-C-00037; AWTP Sludge Drying Bed Improvements-Sheltered Mkt Pre-Bid Conf. 8-6-13 10:00

## 1<mark>3-C-00038; A</mark>WTP New Primary Sludge Pump Station Rehabilitation-Sheltered Market

		as a Bidder and E-Mail All Questions to	
	Sign-In Sheet 🖃 Please Print		City of Tampa, Contract Administration Department
	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	
2	Kerrick Williams	KwPConstruction Video	
3	Robert Lightser	F.E.L. Inc.	reckorph & embar Kmail, com
4	Kaymond Kogers	DANUS Utilities	Danus 1@cfl.rr.com
5	HATRICK WELLS	FLORIDA SEAUNS PROD.	pwells@Floridasealing.com
6	HATS LANGFORD	LoL SETT SURVICENS LIC	Ilsite @ verizon. net
7:	Jenny Langford	LGL Site Services LUC	11 site = verizon net
8	Eddie Granger	Granger Maint,	eddie granger @ granger maint. com
9	Mike Maloy	COT/CAD	813-323-2658
10	Rick Morriss	COT/CAD	813 - 670 - 7912
11	EVENTICE MCDONA	AREFAX Engineering	
12	Daniel Rivera ()	WW Cot (	813-274-8934 Dahiel . Rivera D. Tanggov.
13	JACK FERRAS	WW COT	B13-274-3095 10000
14			
15			
16			·
17			
18			
19			
20			
21			
22			
23			
24			
26			
7			
8			
9			
0			
1			
2			
3			
4			
+-			
5			