



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 1

DATE: June 11, 2014

Contract 14-C-00040; Howard F. Curren AWTP Effluent Water Strainers Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: Replace Proposal page P-3 with the attached Proposal page P-3R.
- Item 2: SP-16-TP Salvage – delete the second and third sentence in the first paragraph. In the second paragraph, third sentence, change 'coat' to 'cost'.
- Item 3: Strainer Weight Clarification: See attached cut sheet that shows the approximate weight of the existing strainer. The proposed strainer is an exact replica with similar weights.
- Item 4: Attached for reference is the pre-bid meeting sign-in sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

\_\_\_\_\_  
Jim Greiner, P.E., Contract Management Supervisor


Contract 14-C-00040; Howard F. Curren AWTP Effluent Water Strainers Replacement

Contract Item No.	Estimated Quantity	Description and Price in Words	Computed Total Price for Item in Figures
BASE BID	LS	<p>The work shall include but not be limited to removal and replacement of two (2) 30" strainers including associated accessory equipment, valve assemblies, electrical connections and appurtenances, any Contingency Allowances as stated in SP-60, with all associated work required for a complete project in accordance with the Contract Documents.</p>	
		<p>_____ dollars</p>	
		<p>and _____ cents</p>	
		<p>(BASE BID)      LS                      \$ _____</p>	

REV	DATE	CHANGE	ECR	BY	APP
A	10/06/94	NEW ISSUE		VA	
B	10/17/94	ADDED FOOT PAD ARRANGEMENT (PLAN VIEW) - FOR QUOTE 9/1137		FC	VA
C	03/13/95	1. ADDED BACKFLUSH 3" FLG. 2 PLACES 2. ADDED SLOT SIZE 3. ADDED SALES NO.		VA	
D	05/01/95	1. ADDED MOTOR VIEW. 2 PLACES 2. ADDED QUANTITY 3. ADDED HAYWARD PART NUMBER 4. REVISED BACKWASH OUTLET (4 PLACES) 5. REVISED CUSTOMER 6. ADDED TABLE AND BALLOONS	3339	VA	

- NOTES:
- FOR REPLACEMENT PARTS, MODEL NO., SIZE AND SERIAL NO. FROM THE STRAINER NAMEPLATE MUST BE FURNISHED.
  - FLANGED CONNECTIONS CONFORM TO ANSI STANDARDS.
  - ALL WEIGHTS IN POUNDS, ALL DIMENSIONS IN INCHES.  
SHIPPING WEIGHT: 8750 POUNDS  
FLOODED WEIGHT: 18150 POUNDS  
COVER WEIGHT: 3000 POUNDS

CUSTOMER: FLORIDA ENGINEERING AND DESIGN/CITY OF TAMPA  
P.O. NO.: 94-0295-01  
SALES NO.: 26277  
QUOTE NO.: 94/1137  
STRAINER QUANTITY: TWO (2)  
STRAINER MATERIALS: BODY AND COVER - CARBON STEEL  
INTERNAL - STAINLESS STEEL  
SUPPORT RING CAST IRON  
INTERNAL EPOXY COATING PER HAYWARD SPEC. ES-302  
EXTERNAL COATING PER HAYWARD SPEC. ES-309  
ELEMENT: 316 STAINLESS STEEL, 1/32" SLOT DURAWEDGE  
HAYWARD PART NO.: 5963004000




**HAYWARD INDUSTRIAL PRODUCTS, INC.**  
900 FAIRMOUNT AVENUE, ELIZABETH, NEW JERSEY 07207

NAME: 30" MODEL 596LDP FABRICATED AUTOMATIC STRAINER - SPECIAL

DRAWN: VAA DATE: 10/06/94 CHECKED: VH DATE: 10/06/94  
SCALE: NTS PROJ: 94/1137

DWG NO	REV
	D



ITEM	QTY.	DESCRIPTION	MATERIAL
1	1	BACKFLUSH INLET FLANGE	STAINLESS STEEL
2	1	BACKFLUSH HOUSING	DUCTILE IRON
3	1	LOWER BACKFLUSH HOUSING	STAINLESS STEEL
4	2	BACKFLUSH ARM	STAINLESS STEEL
5	1	BACKWASH ARM	STAINLESS STEEL
6	1	BACKWASH SHAFT	STAINLESS STEEL
7	1	STRAINING ELEMENT	STAINLESS STEEL
8	1	O-RING	BUNA - N

UNAUTHORIZED USE, MANUFACTURE OR REPRODUCTION IN WHOLE OR IN PART IS PROHIBITED. DRAWING DESIGN AND OTHER DISCLOSURES PROPERTY OF HAYWARD INDUSTRIAL PRODUCTS, INC.

E-Mail to Register as a Plan Holder and E-Mail All Questions to: [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net)

Sign-In Sheet  Please Print

City of Tampa, Contract Administration Department

	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	jody.gray@tampagov.net
2	Joe Spencer	COT	Joe.Spencer@Tampagov.net
3	Rick Cole	← RECORD	R.M.COLE.ENG@GMAIL.COM
4	Tom Secord	Secord Contracting Corp	tsecord@verizon.net
5	JOHNNY GRANGER	GRANGER MAINT. + CONST.	JOHNNY GRANGER@GRANGERMAINT.COM
6	Arlyn Acosta	Gonzalez and Sons.	arlyn.a@gonzalezandsons.net
7	JACK FERRAS	CITY OF TAMPA - DESIGN	JACK.FERRAS@TAMPAGOV.NET
8	ROMAN KORCHAK	C.O.T. ENR.C. DES.	ROMAN.KORCHAK@TAMPAGOV.NET
9	Michael Salgado	C.O.T. - Design	Michael.F.Salgado@tampagov.net
10	Thomas Kemink	RTD construction	813 783 9119
11	Rick Morriss	COT/CAD	813 - 630-3912
12	Mike Maloy	COT/CAD	813 - 323 - 2658
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			