CITY OF TAMPA



Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: December 29, 2014

Contract 15-C-00004; Stormwater SCADA System Expansion

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: A field visit has been scheduled for all the locations at 9:00 AM on Tuesday, January 6, 2015. We will meet at the Penalty Lake Pump station (11402 W. Elbow Drive) and proceed by caravan to the other locations.
- Item 2: At Robles Park Stormwater PS, Drawing E-10 Keyed Notes 1: Level transmitters for monitoring the "Manhole water level" and "Pond water level" are mentioned. The phrase "Manhole water level" was a carryover from previous iterations of the plans set. There is only a pond level to be monitored.
- Item 3: Applications are not available for the Ge Fanuc 9030 and Allen-Bradley PLCs.
- Item 4: Attached for reference is the pre-bid meeting sign-in sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner, P.E., Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080



E-Mail to Register as a Plan Holder and E-Mail All Questions to; ContractAdministration@tampagov.net City of Tampa, Contract Administration Department Sign-In Sheet
Please Print E-Mail OR Phone Organization Name Jim.Greiner@tampagov.net Jim Greiner, PE Tampa Contract Administration Dept. Jody.Gray@tampagov.net Tampa Contract Administration Dept. Jody Gray Allen: Gray@tampagov:net Tampa Contract Administration Dept. Allen Gray 3 FRAIK. WOODARDE TAMPAGOVING MODDARD CHD BHALLED EDTI. COM SKENDRICKE EDTI. COM CMAXWELL & SCADONRICOM ScadaOne Waymire @ Scadaone. com ATRUTILL @TAMPABAY, ER, COM TAMCO ELECTRIC IBENTUN @ DCRENS. con DCR ENSINCERING DCR Engineerly RLee @ dereng.com 13 15 16 18 20 21 22 23 24 25 26 28 29 30 31 32 33