



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

ADDENDUM NO. 1

DATE: February 25, 2016

Contract 15-C-00042; Howard F. Curren AWTP Digestion Control Building "A" MCC Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Magnetic Flow Meter and Transmitter Clarification:

The model number for the magnetic flow meter is
FEP325.150.H.1.S.1.A1.B.1.K.1.C.4.R.3.B.O.Y.1-AY.J1.F6....M5.

The model number for the transmitter is FEP325.1.C.0.P.1.B.3.B.0-H1....M5.

Item 2: Gas Detector Clarification:

In plan sheet 7 and Workmanship and Materials Section W46, the part number for the Gas Detector Det-Tronics PIR 900 Series is PIR9400S3A1AW.

Item 3: Delete the Sign Details. A project sign will not be required for this project.

Item 4: Page I-1b – Delete the first sentence, which states “The awardee must be a licensed Underground Utility and Excavation Contractor.”

Item 5: Attached for reference is a copy of the pre-bid meeting sign-in sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

CONTRACT 15-C-00042; Digestion Control Bldg A MCC Replacement Pre-Bid 2-16-16, 10:00

E-Mail to Register as a Plan Holder and E-Mail All Questions to: ContractAdministration@tampagov.net

Sign-In Sheet Please Print

City of Tampa, Contract Administration Department

	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	jody.gray@tampagov.net
3	BOB HALLMAN	EDT	BHALL@EDT1.COM
4	Bill Mowery	COT	5559@Tampagov.net
5	JAMES MORENO	COT	5594@tampagov.net
6	Ayyappan Pillai	JAIN Group Intl	ayyappanpillai@hotmail.com
7	SCOTT BARBER	MSM ELECTRIC, INC	SCOTT.BARBER@MSMELECT.COM
8	Zach Sechrist	MSM Electric	ZACH.SECHRIST@MSMELECT.COM
9	Steve Antman	C E Power Solutions	steve.antman@cepower.net
10	Daniel Pate	LEW	dp@leedywest.com
11	Kewin Schell	COT AWTP	Kewin.Schell@Tampagov.net
12	Joe Striker	COT AWTP	Joseph.Striker@Tampagov.net
13	Mike Maloy	COT / CAD	Michael.Maloy@Tampagov.net
14	Rick Morris	COT / CAD	
15	BRIAN STEWART	TPS	brianstewart@verizon.net
16	Mark Johnson	COT / CAD	Mark.Johnson@Tampagov.net
17	Rob Decky	COT	
18	VANN DOUGLAS	SOUTHERN INDUSTRIAL ELECTRIC	VANN@SOIELECTRIC.COM
19	Clay Fitzgerald	Southern Ind. Electric	clay@SOIElectric.com
20	Andy Griffin	Southern Industal Elec.	awgriffi99@gmail.com
21	CARMEN RODRIGUEZ	COT - CAD	carmen.rodriguez@tampagov.net
22	JACK FERRAS	COT - DESIGN	JACK.FERRAS@TAMPAGOV.NET
23	DOUG ERWIN	Erwin Electric	Doug@ErwinElectric.com
24	ROMAN KORCHAK	C.O.T WW DEP. ENGR	Roman.KORCHAK@TAMPAGOV.NET
25	Lashonda Green	C.O.T WW. Pep.	lashonda.green@tampagov.net
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			