CITY OF TAMPA



Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

ADDENDUM 1

DATE: April 4, 2019

Contract 18-C-00023; Hanna Pumping Station Odor Control Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: SP-15 Contractor's Field Office: In the first sentence, Delete "on Page G-14"
- Item 2: SP-68 Water, Light and Power: Change the first sentence to read "Delete Article G-7.01 Water and G-7.02 Light and Power from GENERAL PROVISIONS."
- Item 3: Section 106 - Biological Filter Odor Control System, 106.02 Products, 2.1.6. Biological Media - Add the following:

The media volumes are as follows:

- Approximately 800-900 Cubic Feet of Media in total.
- Tank No. 1 ~ 10,000 lb of Sulfa-Treat Media
- Tank No. 2 ~ 12.000 lb of Sulfa-Treat Media
- Tank No. 3 ~ 1,200 lb of Carbon Media

All existing odor control media (Sulfa-Treat and Carbon) shall be removed and delivered to the Howard F. Curren Advanced Wastewater Treatment Plant. The City will dispose of the media.

Item 4: Attached is the pre-bid meeting sign-in sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner, P.E., Contract Management Supervisor

E-Mail to Register as a Plan Holder and E-Mail All Questions to; ContractAdministration@tampagov.net City of Tampa, Contract Administration Department Sign-In Sheet 🔳 Please Print OR Phone Organization E-Mail Name Jody.Gray@tampagov.net Jody Gray Tampa Contract Administration Dept. TLC Diversitied bids@tlcdiv.com CONSTAUCTION Ampticov. Ne. KIENE DUSWATERCORP. NET SAVIGNY CUTLER BEACH & REBEACH. COM ASSOC GROP EHOG KORCHBIC@THUPPAGOUWET